

Amendment - 3 dated 04.09.2025 to
RFP documents for Selection of Bidder as Transmission service provider for
“Network Expansion scheme in Maharashtra for Evacuation of RE Power from Dharashiv, Beed District”

Sl No	Clause No.	Existing Provisions			Revised Provisions		
1.	Relevant Clauses of RfP and TSA	Scope of the Transmission Scheme:			Scope of the Transmission Scheme:		
		Sl.	Name of the Transmission Element	Scheduled COD in months from Effective Date	Sl.	Name of the Transmission Element	Scheduled COD in months from Effective Date
		1	Establishment of Washi SS with 2x500 MVA, 400/220 kV ICT and 2x300 MVA, 400/132 kV ICT with 1x125 MVAR bus Reactor at 400 kV level. • 400/220 kV, 500 MVA, ICT – 2 Nos. • 400/132 kV, 300 MVA, ICT – 2 Nos. • ...	24 Months	1	Establishment of Washi SS with 2x500 MVA, 400/220 kV ICT and 2x315 MVA, 400/132 kV ICT with 1x125 MVAR bus Reactor at 400 kV level. • 400/220 kV, 500 MVA, ICT – 2 Nos. • 400/132 kV, 315 MVA, ICT – 2 Nos. • ...	24 months
		2	...		2	..	
		3	...		3	...	
		4	...		4	...	
		5	...		5	...	
		6	220 kV bays at Manjarsumba (existing) S/s and Paranda (existing) S/s • 220 kV (AIS) line bay at 220 kV Manjarsumba (existing)- 2 Nos • 220 kV (AIS) line bay at 220 kV Paranda (existing) - 2 Nos		6	220 kV bays at Manjarsumba (existing) S/s and Paranda (existing) S/s • 220 kV (AIS) line bay at 220 kV Manjarsumba (existing)- 2 Nos • 220 kV (GIS) line bay at 220 kV Paranda (existing) - 2 Nos	
		7	...		7	...	
		8	...		8	...	