

**Annexure II: Amendment No. 4 dated 10.10.2025 to the RFP documents for selection of Bidder as Transmission Service Provider
for “Inter-Regional Strengthening between SR Grid and ER Grid”**

S. No.	Existing Provisions			Revised Provisions		
1.	RFP Clause 1.2 & S. No. 2 (Scope of Work) at Page No. 3			RFP Clause 1.2 & S. No. 2 (Scope of Work) at Page No. 3		
	And			And		
	TSA Schedule: 1 (B. Detailed Scope of Work)			TSA Schedule: 1 (B. Detailed Scope of Work)		
	Inter-Regional Strengthening between SR Grid and ER Grid			Inter-Regional Strengthening between SR Grid and ER Grid		
	S. No.	Name of Transmission Element	Scheduled COD in months from Effective Date	S. No.	Name of Transmission Element	Scheduled COD in months from Effective Date
1.	Angul – Srikakulam 765 kV 2 nd D/c line with 240 MVAR SLR at both ends on both circuits 765 kV line bays – 2 Nos. GIS (at Srikakulam) 765 kV line bays – 2 Nos. AIS (at Angul) 765 kV, 240 MVA_r SLR at Srikakulam – 2 Nos. (6x80 MVA_r switchable units) 765 kV, 240 MVA_r SLR at Angul – 2 Nos. (6x80 MVA_r switchable units)	30 Months	1.	Angul – Srikakulam 765 kV 2 nd D/c line with 240 MVAR SLR at both ends on both circuits 765 kV line bays – 2 Nos. GIS (at Srikakulam) 765 kV line bays – 2 Nos. AIS (at Angul) 765 kV, 240 MVA_r SLR at Srikakulam – 2 Nos. (6x80 MVA_r switchable units) 765 kV, 240 MVA_r SLR at Angul – 2 Nos. (7x80 MVA_r switchable units incl. 1 spare unit)	30 Months	
2.	1x330 MVAR, 765 kV bus reactor (3 rd) at Angul Substation 765 kV bus reactor – 1 No. (3x110 MVA_r switchable units)		2.	1x330 MVAR, 765 kV bus reactor (3 rd) at Angul Substation		

Annexure II: Amendment No. 4 dated 10.10.2025 to the RFP documents for selection of Bidder as Transmission Service Provider for “Inter-Regional Strengthening between SR Grid and ER Grid”

S. No.	Existing Provisions			Revised Provisions		
		765 kV bus reactor bay – 1 No.			765 kV bus reactor – 1 No. (3x110 MVar switchable units)	
	Notes: i. POWERGRID shall provide space (free of cost) for 2 Nos. of 765 kV line bays each at Srikakulam (GIS) and Angul for termination of Angul-Srikakulam 765 kV D/c line. ii. POWERGRID shall provide space (free of cost) for 1x330 MVar bus reactor along with associated bay at Angul.			Notes: i. POWERGRID shall provide space (free of cost) for 2 Nos. of 765 kV line bays each at Srikakulam (GIS) and Angul for termination of Angul-Srikakulam 765 kV D/c line. ii. POWERGRID shall provide space (free of cost) for 1x330 MVar bus reactor along with associated bay at Angul.		