

Amendment No. 3 dated 25.01.2022

to

Request for Proposal (RfP) and Transmission Service Agreement (TSA) for selection of Transmission Service Provider through tariff based competitive bidding process for “Transmission system for evacuation of power from Pakaldul HEP in Chenab Valley HEPs - Connectivity System”

S. No.	Existing Provision	Amended Provision
1.	<p>Amendment No. 1 issued on October 14, 2021</p> <p>Annexure-B Technical Specifications of Transmission System of RfP and Schedule-2 of TSA</p> <p>Appendix-1 to Annexure-B: Specific Technical Requirements for Transmission Lines, Substation & Communication System.</p>	<p>Amendment No. 1 issued on October 14, 2021</p> <p>Annexure-B Technical Specifications of Transmission System of RfP and Schedule-2 of TSA</p> <p>Appendix-1: Specific Technical Requirements for Transmission Lines, Substation & Communication System.</p> <p>Technical Specification for 66.67 MVA, I-phase 400/132 kV ICT & 41.67 MVA, 420 kV, I-Phase Bus reactor is enclosed at Appendix-1.</p>